

## 2018年10月废水自动监测结果

日期	COD(60mg/l)		NH3-N(15mg/l)		总氮(20mg/l)		废水流量t/d
	排放平均浓度mg/l	排放量kg	排放平均浓度mg/l	排放量kg	排放平均浓度mg/l	排放量kg	
2018/10/1	11.56	11	3.02	2.89	6.94	6.61	951.46
2018/10/2	12.08	10.67	2.92	2.58	6.92	6.11	881.89
2018/10/3	11.84	13.24	3.04	3.4	7.2	8.08	1117.93
2018/10/4	13.38	15.29	3.45	3.98	6.55	7.51	1142.43
2018/10/5	14.23	13.02	3.63	3.32	7.24	6.6	914.59
2018/10/6	14.42	16.7	3.69	4.29	7.22	9.36	1158.37
2018/10/7	15.46	17.28	4.03	4.49	7.32	8.2	1118.59
2018/10/8	15.13	16.78	4.04	4.46	6.99	7.77	1109.62
2018/10/9	21.49	23.63	4.08	4.5	6.81	7.51	1098.7
2018/10/10	14.61	10.85	4.17	3.11	6.99	5.57	741.43
2018/10/11	17.19	16.92	4.25	4.18	6.85	6.72	983.74
2018/10/12	16.52	19.43	4.94	5.82	7.35	8.67	1176.73
2018/10/13	17.28	18.05	4.98	5.2	7.05	7.83	1046.47
2018/10/14	17.94	15.12	4.77	4.01	6.48	5.46	842.32
2018/10/15	18.99	18.51	4.96	4.83	6.83	6.65	974.77
2018/10/16	19.81	17.91	5.26	4.77	6.67	6.05	905.35
2018/10/17	20.1	15.81	5.18	4.06	6.44	5.06	786.87
2018/10/18	20.99	12.78	5.19	3.23	6.03	3.56	619.65
2018/10/19	21.5	12.11	5.64	3.35	5.94	3.08	550.46
2018/10/20	21.54	21.10	7.37	7.2	6.48	6.33	978.95
2018/10/21	21.23	19.62	7.46	6.9	6.53	6.04	925.6
2018/10/22	21.63	21.64	7.35	7.15	6.55	6.36	972.77
2018/10/23	21.15	19.35	7.03	6.45	9.35	8.54	914.68
2018/10/24	20.83	21.84	7.55	7.92	9.23	9.66	1048.09
2018/10/25	20.77	20.74	8.34	8.29	8.21	8.19	999.33
2018/10/26	16.92	15.05	7.38	6.57	9.06	8.04	888.7
2018/10/27	12.73	12.56	6.97	6.89	8.46	8.35	986.85
2018/10/28	12.56	10.44	7.14	6.07	7.62	6.51	853.36
2018/10/29	12.94	13.36	7.83	7.79	8.02	8.3	1031.2
2018/10/30	12.01	11.75	7.83	7.66	8.32	8.13	976.23
2018/10/31	13.65	12.14	7.99	7.1	8.36	7.4	889.37